

Public Water System Service Line Inventory Form-version 1.0

Building Plumbing Material	Service Line Material	
G-Galvanized	P - Plastic	G - Galvanized
C - Copper w/non-lead solder	C - Copper	Lead
CLS - Copper with lead solder	UNK - Unknown	DI - Ductile Iron
O - does not contain Pb solder-Cu-galvanized	UNK-NOLG - Unknown - Unlikely to contain lead or galvanized	CI-L - Lined Cast Iron
UNK - Unknown	UNK-LG - Unknown - May contain lead and/or galvanized	CI-U - Unlined Cast Iron

Type	Total
Non-Lead	0
Lead	38
GRR	2
Unknown	0
Pb Connectors	0
Replaced Pb Connectors	0
Unknown Connectors	76

PWS Name NAVMAG Lualualei **Last Updated:** 11/7/2024

Location NAVMAG Lualualei

Site ID (other unique identifier)	Current Public Service Line Material (PWS Owned) (if 2 different materials fill out both columns)		Was Public Service Line Material Ever Previously Lead?	Current Customer Service Line Material (if 2 different materials fill out both columns)		Overall
	Material 1	Material 2		Material 1	Material 2	
10	G		Unknown	G		GRR
102	G		Unknown	G		GRR
103	C		Unknown	C		Non-Lead
110	C		Unknown	C		Non-Lead
112	C		Unknown	C		Non-Lead
113	G		Unknown	G		GRR
114	G		Unknown	G		GRR
161	C		Unknown	C		Non-Lead
1A- 1	DI		No	DI		Non-Lead
1A- 2	C		Unknown	C		Non-Lead
2	G		Unknown	G		GRR
25	C		Unknown	G		GRR
258	G		Unknown	G		GRR
27	G		No	G		Non-Lead
28	P		Unknown	P		Non-Lead
28- 1	DI		No	DI		Non-Lead
28- 2	C		Unknown	C		Non-Lead
3	UNK		Unknown	UNK		UNK
32	G		Unknown	G		GRR
385	G		Unknown	G		GRR
387	G		Unknown	G		GRR
4	C		Unknown	C		Non-Lead
413	C		Unknown	C		Non-Lead
421- 1	G		Unknown	G		GRR
421- 2	G		Unknown	C		Non-Lead
439	G		Unknown	G		GRR
441- 1	G		Unknown	C		Non-Lead
441- 2	C		Unknown	C		Non-Lead
442	C		Unknown	C		Non-Lead
444	G		No	G		Non-Lead
471	C		Unknown	C		Non-Lead
472- 1	DI		No	G		Non-Lead
472- 2	DI		No	G		Non-Lead
472- 3	G		Unknown	G		GRR
475A	DI		No	C		Non-Lead
492- 1	DI		No	DI		Non-Lead
492- 2	G		No	G		Non-Lead
4A	G		Unknown	C		Non-Lead
5	G		Unknown	G		GRR

Site ID (other unique identifier)	Current Public Service Line Material (PWS Owned) (if 2 different materials fill out both columns)		Was Public Service Line Material Ever Previously Lead?	Current Customer Service Line Material (if 2 different materials fill out both columns)		Overall
	Material 1	Material 2		Material 1	Material 2	
520	G		Unknown	G		GRR
547	P		Unknown	P		Non-Lead
551	C		Unknown	C		Non-Lead
5A	G		Unknown	G		GRR
6	G		Unknown	G		GRR
68	UNK		Unknown	UNK		UNK
77	G		Unknown	G		GRR
81- 1	P		Unknown	P		Non-Lead
81- 2	G		Unknown	G		GRR
A102- 1	G		Unknown	G		GRR
A102- 2	G		Unknown	G		GRR
A250	DI		No	DI		Non-Lead
D122	G		No	G		Non-Lead
F102	G		Unknown	G		GRR
S463	G		Unknown	G		GRR
8	C		Unknown	C		Non-Lead
415	C		Unknown	C		Non-Lead
67	C		Unknown	C		Non-Lead
66	C		Unknown	C		Non-Lead
111	C		Unknown	C		Non-Lead
112	DI		No	DI		Non-Lead
10A	G		Unknown	G		GRR
11	G		Unknown	G		GRR
12A	G		Unknown	G		GRR
6A	G		Unknown	G		GRR
7	G		Unknown	G		GRR
8B	G		Unknown	G		GRR
9A	G		Unknown	G		GRR
17	G		Unknown	G		GRR
17A	G		Unknown	G		GRR
17B	G		Unknown	G		GRR
Q-A	G		Unknown	G		GRR
Q-B	G		Unknown	G		GRR
Q-C	G		Unknown	G		GRR
Q-D	G		Unknown	G		GRR
Q-E	G		Unknown	G		GRR
Q-F	C		Unknown	C		Non-Lead
Q-G	C		Unknown	C		Non-Lead
Q-H	C		Unknown	C		Non-Lead
Q-J	C		Unknown	C		Non-Lead
Q-K	C		Unknown	C		Non-Lead
Q-L	C		Unknown	C		Non-Lead
Q-M	C		Unknown	C		Non-Lead
Q-N	C		Unknown	C		Non-Lead

PWS Name NAVMAG Lualualei

Last Updated: 11/7/2024

Location NAVMAG Lualualei

Site ID (other unique identifier)	Current Public Service Line Material (PWS Owned) (if 2 different materials fill out both columns)		Was Public Service Line Material Ever Previously Lead?	Current Customer Service Line Material (if 2 different materials fill out both columns)		Overall
	Material 1	Material 2		Material 1	Material 2	
Q-O	C		Unknown	C		Non-Lead

End of Records - Copy Blank Rows from Above and Insert New Rows above this line as needed