



# Water Quality Report

## Joint Base Pearl Harbor-Hickam Water System

(Waiawa, Navy Aiea-Halawa & Red Hill Sources)

This report meets federal and state requirements for Consumer Confidence Reports. This report is updated annually and reflects monitoring data collected from Jan 1 - Dec 31, 2025.

The Navy is pleased to provide you with this year's annual Water Quality Report for the Joint Base Pearl Harbor-Hickam (JBPHH) Drinking Water System.

This pamphlet provides information about the water delivered to you during the 2025 calendar year. It gives information on where your water comes from, what it contains, and how it compares to established standards for safe drinking water.

All drinking water for JBPHH came from the Waiawa Shaft during this reporting period.

The Navy's goal is to provide you with safe and dependable drinking water.

### Water Provider

Naval Facilities Engineering Systems Command (NAVFAC) Hawaii operates the water system servicing your area. As the Navy water provider in the State of Hawaii (State), we primarily supply water to military installations and housing.

### Drinking Water Standards

To protect public health, the Environmental Protection Agency (EPA) prescribes regulations which limit the number of certain contaminants in tap water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

In this latest compliance monitoring period, we conducted tests for over 70 contaminants that have the potential to be found in your drinking water. Tables 1-1, 1-2, 1-3, 1-4, 1-5, 1-6, and 1-7 show the concentration levels of regulated contaminants found in your water. In all cases, the levels measured were below EPA and State requirements for safe drinking water.

We are continually working to protect your drinking water from contaminants. The State's Department of Health (DOH) completed the Source Water Assessment in 2004 which identifies the susceptibility of your water supply to contamination. The source water assessment is available for review by emailing the JBPHH Public Affairs at Charles.J.Anthony.civ@us.navy.mil.

### Source of Water

Historically, your drinking water came from the Waimalu and Moanalua groundwater aquifer systems via three supply wells/shafts: Waiawa, Navy Aiea-Halawa, and Red Hill. Groundwater is naturally filtered as it travels from the surface to the aquifers below ground. The water is pumped up from the aquifer, disinfected, fluoridated, and piped into the JBPHH drinking water distribution system.

The Red Hill and Navy Aiea-Halawa shafts were taken offline on November 28, 2021, and December 3, 2021, respectively, following the Red Hill Shaft Incident (see page 2). Since December 3, 2021, drinking water for the JBPHH Water System has been supplied solely by the water from the Waiawa Shaft.

### Possible Source of Contaminants

Both tap water and bottled water come from rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material. The water can also pick up and transport substances resulting from the presence of animals or from human activity. These substances are also called contaminants.

### Possible Source of Contaminants in Bottled Water

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily mean that water poses a health risk. More information about contaminants and potential health effects can be obtained by contacting the EPA by calling the Safe Drinking Water Hotline (800-426-4791).

### Potential Contaminants

**Contaminants** are any physical, chemical, biological, or radiological substance or matter in water.

**Contaminants that may be present in your source water include:**

**Microbial contaminants** – such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants** – such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides** – which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants** – including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radionuclide contaminants** – which can be naturally-occurring or be the result of oil and gas production and mining activities.

**Lead** can cause serious health effects in people of all ages, especially pregnant women, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing.

### Navy Water Requirements

In accordance with Navy policy, chlorine and fluoride are added to your water supply after the water is pumped from the ground. The Navy's goal is to maintain concentrations of approximately 0.7 parts per million (ppm) for fluoride and 0.2 ppm for chlorine throughout the distribution system.

### 2021 Red Hill Shaft Incident

In November 2021, families supported by the Joint Base Pearl Harbor-Hickam (JBPHH) drinking water system reported petroleum odors coming from residential tap water supplied by the U.S. Navy water system to state and federal regulators.

The source of the petroleum was the nearby Red Hill Bulk Fuel Storage Facility, which contaminated the Red Hill Shaft, one of the Navy's production wells for the Joint Base Pearl Harbor Hickam drinking water system. In response, the Navy disconnected the Red Hill Shaft. The Navy Aiea-Halawa Shaft was also disconnected from the drinking water system in December 2021 out of an abundance of caution following the Red Hill incident. The Waiawa Shaft became the sole source of water for the JBPHH Drinking Water System which serves more than 90,000 customers.

An Interagency Drinking Water System Team (IDWST) was established with representatives from the EPA, the Navy, The Army and the State. The IDWST implemented a set of plans and corrective actions to ensure safe drinking water and restore/recover the drinking water system. The plans included:

#### Red Hill Shaft Recovery and Monitoring Plan

<https://www.cpf.navy.mil/Portals/52/Downloads/JBPHH-Water-Updates/2022-01-26-red-hill-shaft-recovery-and-monitoring-plan.pdf>

#### Drinking Water Distribution Recovery Plan

<https://www.cpf.navy.mil/Portals/52/Drinking-Water-Distribution-System-Recovery-Plan.pdf>

#### Drinking Water Sampling Plan

[https://www.cpf.navy.mil/Portals/52/Downloads/JBPHH-Water-Updates/Drinking%20Water%20Sampling%20Plan%20Addendum\\_V6\\_010422\\_Final2.pdf?ver=lHgyhCw68Io4cd8FtQAuEA%3d%3d](https://www.cpf.navy.mil/Portals/52/Downloads/JBPHH-Water-Updates/Drinking%20Water%20Sampling%20Plan%20Addendum_V6_010422_Final2.pdf?ver=lHgyhCw68Io4cd8FtQAuEA%3d%3d)

The Drinking Water Distribution System Recovery Plan divided the JBPHH Water System and Aliamanu Military Reservation Water System into 19 zones and detailed standard operating procedures for the flushing and sampling of each of the zones during the recovery effort in 2022. High-volume flushing of the Navy drinking water distribution system (all water mains/laterals/buildings) with 3 to 5 volumes of clean water from the Waiawa Shaft was conducted to restore safe drinking water to all Navy Water System users. Other corrective measures, such as fixture replacement, were also implemented where appropriate.

On March 18, 2022, after verification of recovery efforts and a thorough review of sample results, the State amended the health advisory and declared the drinking water safe for all 19 zones. To ensure a continuous supply of safe drinking water, the Navy implemented its Long-Term Monitoring (LTM) plan that spanned 24 months until February 2024. All drinking water sampling results are compiled and published on our Safe Waters website (see link below) designed to provide public access to the most recent data reports and updates to the ongoing efforts to maintain safe drinking water.

Sampling results will also be included in future Water Quality Reports: [www.cpf.navy.mil/JBPHH-Water-Updates/](http://www.cpf.navy.mil/JBPHH-Water-Updates/)

The Extended Drinking Water Monitoring (EDWM) plan reflected the most current sampling procedures and requirements established by the Navy and regulators. Under this program, additional sampling of the source, distribution lines, houses, along with schools, child development centers, and medical/dental/veterinary offices continued beyond LTM for an additional 12 months. The EDWM plan focused on JP-5 and other fuel-related analytes along with some additional drinking water analytes. The program also increased the number of zones being sampled from the original 19 to 20 by including Manana Housing.

The EDWM ended in March 2025. In March of 2026, after reviewing the laboratory data from both the LTM and EDWM, EPA endorsed the closure of both sampling programs and confirm that JP-5 is no longer present in the JBPHH drinking water system.

### Inactive Interconnect at Red Hill Shaft

During the May 2025 sanitary survey of the JBPHH water system, DOH identified a significant deficiency in the currently inactive Red Hill Shaft. The finding outlined that there are backflow-related contamination risks from an inactive Board of Water Supply (BWS) interconnect. The BWS interconnect has not been in use since the 2021 Red Hill Shaft incident and has been physically disconnected from the BWS side of the connection. Concerns of stagnant water getting into the distribution system were raised during the inspection and the Navy is aiming to fully disconnect the unused interconnect prior to reactivating the Red Hill Shaft.

Red Hill Shaft has been and remains inactive. This means that there are currently no potential risks to water quality due to this finding from DOH.

### Drinking Water Service Line Material Inventory

The Navy has completed the baseline inventories for each of its water systems. You can access the inventory yourself for your water system by visiting the link below. For privacy reasons, the exact street addresses have been replaced with unique Site IDs. Additionally, if you were identified to be served by a lead service line, galvanized requiring replacement (GRR) service line or lead-status unknown service line, you should have been notified in a letter from November 2024. You may also contact JBPHH Public Affairs via email at [Charles.J.Anthony.civ@us.navy.mil](mailto:Charles.J.Anthony.civ@us.navy.mil) to inquire what material you are being served by.

#### The baseline inventory is accessible here:

<https://cnrh.cnrc.navy.mil/Operations-and-Management/Environmental/Water-Quality-Information/Drinking-Water-Service-Line-Materials-Inventory/>

Concurrent to the baseline inventory compliance date, the EPA enacted the Lead and Copper Rule Improvements (LCRI) on October 9, 2024, further strengthening the LCRR protection by introducing additional safeguards and setting a more aggressive timeline for replacing the lead or galvanized lines.

As such, the Navy's water systems must provide the updated baseline inventory to include the connector material along with the service line material inventory by November 1, 2027. The inventory will also be updated periodically to reflect the Navy's progress to remove any lead or galvanized materials service lines and connectors that are encountered.

### Drinking Water Service Line Material Replacement Plan

In accordance with 40 CFR 141.84(c), all water systems with one or more lead, galvanized requiring replacement, or lead status unknown service lines in their distribution system must create a service line replacement plan by no later than November 1, 2027.

### Corrosion and Optimal Corrosion Control Treatment (OCCT)

Corrosion of pipes, plumbing fittings, and fixtures may cause lead and copper to enter drinking water. To assess corrosion of lead and copper, JBPHH Water System conducts tap sampling for lead and copper at selected sites every 3 years.

The JBPHH Water System is considered to meet OCCT because its most recent tap sampling results from September 2024 show that the 90<sup>th</sup> percentile lead level was non-detect. This means that 90% of the highest lead levels detected were at or below the limit of detection. Please see Table 1-2 for the Copper 90% percentile level.

### Safeguard Against Lead

[The Navy is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes.

If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, please contact the JBPHH Drinking Water Call Center at (808) 210-6968. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>

### Lead Sampling in Schools

Beginning November 1, 2027, all Community Water Systems, the same systems that provide these annual Water Quality Reports (WQR), will be required to conduct sampling for lead in drinking water at schools and childcare facilities. Facilities that are being served by this water system are encouraged to contact the Navy to ensure that their school or childcare facility will be included in the sampling effort.

However, the Navy has already adopted a policy to perform lead sampling at schools and childcare facilities owned by the Department of Defense (DoD).

#### Please visit this website for more information:

<https://cnrh.cnrc.navy.mil/Operations-and-Management/Environmental/Water-Quality-Information/Lead-in-Priority-Area-Sampling-Program/>

### Public Discussion Opportunities

While there are no regularly scheduled meetings for discussions regarding the Joint Base Pearl Harbor Hickam Water System, the public may communicate concerns related to water quality by emailing the JBPHH Public Affairs Office listed below.

### What are per- and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industries and consumer products around the globe, including in the U.S., since the 1940s. PFAS are found in many consumer products, as well as in industrial products, like certain firefighting agents called aqueous film forming foam (AFFF). PFAS is also found in essential use applications such as microelectronics, batteries, and medical equipment. PFAS chemicals are persistent in the environment, and some are persistent in the human body – meaning they do not break down and they can accumulate over time.

## Is there a regulation for PFAS in drinking water?

On April 26, 2024, EPA published a National Primary Drinking Water Regulation (NPDWR) final rule on drinking water standards for six PFAS under the Safe Drinking Water Act (SDWA). The rule establishes the following maximum contaminant levels (MCLs):

- Perfluorooctane sulfonic acid (PFOS) = 4 ppt
- Perfluorooctanoic acid (PFOA) = 4 ppt
- Hexafluoropropylene oxide dimer acid (HFPO-DA, commonly known as GenX) = 10 ppt
- Perfluorononanoic acid (PFNA) = 10 ppt
- Perfluorohexane sulfonic acid (PFHxS) = 10 ppt
- Hazard Index (HI) MCL for PFHxS, PFNA, perfluorobutane sulfonic acid (PFBS), and GenX = 1 (unitless).

Under the NPDWR, regulated public water systems (PWS) are required to complete initial monitoring by April 26, 2027. Beginning April 26, 2027, regulated PWSs will conduct ongoing compliance monitoring in accordance with the frequency dictated by the rule and as determined by the initial compliance monitoring results. Regulated PWSs must demonstrate compliance with the MCLs by April 26, 2029.

To provide safe drinking water to all DoD personnel, the policy of the Office of Secretary of Defense extends this requirement to all DoD systems which provide drinking water for human consumption, regardless of size of the drinking water system. In addition to the six regulated compounds, DoD-owned systems are required by DoD policy to monitor for all 25 compounds detected when using EPA Method 533.

Protecting the health of our personnel, their families, and the communities in which we serve is a priority for the Department. DoD is committed to complying with requirements of the NPDWR and the continued provision of safe drinking water to those that work and live on DoD installations.

## Has the JBPHH Water System tested its water for PFAS in 2025?

Yes, the Navy conducts internal bi-monthly PFAS sampling for the active Waiawa Shaft. This sampling effort started in July 2024 and is an ongoing effort to ensure that water provided by the Waiawa Shaft is compliant with current DoD policy, as well as upcoming EPA PFAS regulations. In 2024, samples were taken in July, September and November. The 2024 sample results showed no exceedances of the MCLs for each of the regulated PFAS contaminants.

## What is Next?

The JBPHH Water System will continue to monitor PFAS in accordance with the EPA regulation and DoD policy. Once required initial monitoring information is available, we will calculate the Running Annual Averages (RAA) for the regulated PFAS and will compare those numbers to the MCL and Hazard Index (HI) trigger levels. This will determine what our continuing monitoring requirements will be beginning in 2027, and if needed, we will plan operational or infrastructure changes to ensure our water complies with the PFAS MCLs and HI by April 2029 in accordance with the SDWA.

**For questions, concerns or hard copies, please contact:**

**JBPHH Public Affairs Office (PAO)**  
**Telephone: 808-371-5189**  
**Email: Charles.J.Anthony.civ@us.navy.mil**

**For additional copies of this and other Navy water reports, visit:**

<https://cnrh.cnrc.navy.mil/Operations-and-Management/Environmental/Water-Quality-Information/>

Please share this information with all other people who drink this water, especially those who may not have received this notice directly.

## Official Address

**Joint Base Pearl Harbor-Hickam**  
**850 Ticonderoga St., STE 200**  
**Pearl Harbor, HI 96860-5102**

**Printed June 2026**

# Water Quality Data Table

The following tables list contaminants that were detected during the latest compliance sampling period (Jan 1, 2022– Dec 31, 2025) required by EPA and State regulations. The water samples were collected from either the source water or distribution system and analyzed by the State, BWS and/or the Navy. The presence of contaminants does not necessarily indicate that the water poses a health risk. Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. You can obtain more information about contaminants and potential health effects by calling the EPA’s Safe Drinking Water Hotline 1-800-426-4791 or the State’s Department of Health at 808-586-4258.

**Contaminants in the Navy’s Source Water**

**Table 1-1**

Contaminants (units)	MCL (Allowed)	MCLG (Goal)	Highest Level Detected	Range of Detection	Year of Sample	Typical Sources of Contaminants	Violation	# of Sites Exceeding the Action Level
<b>Inorganic Contaminants</b>								
Fluoride (ppm)	4	4	0.44	0.23 – 0.44	2025	Erosion of natural deposits; Water additive which promotes strong teeth	No	0
Copper (ppm)	AL = 1.3	1.3	0.23	0.23 <sup>1</sup>	2025	Corrosion of household plumbing systems; Erosion of natural deposits	No	0
Nitrate (ppm)	10	10	0.50	0.50 <sup>1</sup>	2025	Runoff from fertilizer use; Erosion of natural deposits	No	0
<b>Organic Contaminants</b>								
Di(2-ethylhexyl) phthalate (ppb)	6	6	1.4	1.4 <sup>1</sup>	2024	Discharge from rubber and chemical factories	No	0
<b>Unregulated Contaminants</b>								
Chloride (ppm)	250 <sup>6</sup>	n/a	40.4	32.2 – 40.4	2025	Naturally occurring	n/a	0
Sodium (ppm)	n/a <sup>3</sup>	n/a	24.7	24.7 <sup>1</sup>	2025	Naturally occurring	n/a	0
Sulfate (ppm)	250 <sup>4,6</sup>	n/a	6.35	6.35 <sup>1</sup>	2024	Naturally occurring	n/a	0
Zinc (ppm)	5 <sup>6</sup>	n/a	0.07	0.07 <sup>1</sup>	2024	Naturally occurring	n/a	0
<b>UMCR5</b>								
Lithium (ppb)	n/a <sup>3</sup>	n/a	ND	ND	2023 <sup>2</sup>	Naturally occurring metal that may concentrate in brine waters	n/a	0
Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (PFAS)	n/a <sup>3</sup>	n/a	ND	ND	2023 <sup>2</sup>	Synthetic chemicals used in a wide range of consumer products and industrial applications	n/a	0

**Contaminants in the Navy’s Distribution System**

**Table 1-1**

Contaminants (units)	MCL (Allowed)	MCLG (Goal)	Highest Level Detected	Range of Detection	Year of Sample	Typical Sources of Contaminants	Violation	# of Sites Exceeding the Action Level
<b>Inorganic Contaminants</b>								
Copper (ppm)	AL = 1.3	1.3	0.139 <sup>5</sup>	ND – 0.164	2024	Corrosion of household plumbing systems; Erosion of natural deposits	No	0
Fluoride (ppm)	4	4	0.44	0.23 – 0.44	2025	Erosion of natural deposits; Water additive which promotes strong teeth	No	0

**Contaminants in the BWS Source Water (Serving Manana Housing)**

**Table 1-2**

Contaminants (units)	MCL (Allowed)	MCLG (Goal) <sup>2</sup>	Highest Average Level Detected	Range of Detection	Year of Sample	Typical Sources of Contaminants	Violation	# of Sites Exceeding the Action Level
<b>Regulated Contaminants</b>								
1,2,3-Trichloropropane (ppb)	0.6	0	0.048	0.028 – 0.057	2024	Fumigant previously used in agriculture	No	0
Barium (ppm)	2	2	0.004	0.003 – 0.004	2023 <sup>2</sup>	Erosion of natural deposits	No	0
Chromium (ppb)	100	100	0.975	ND – 1.200	2022 <sup>2</sup>	Naturally occurring	No	0
Fluoride (ppm)	4	4	0.075	0.061 – 0.075	2024	Erosion of natural deposits; Water additive which promotes strong teeth	No	0
Nitrate (ppm)	10	10	0.770	0.7 – 0.77	2024	Runoff from fertilizer use; Erosion of natural deposits	No	0
<b>Unregulated Contaminants</b>								
Chlorate (ppb)	210 <sup>6</sup>	n/a	71.0	30.0 – 71	2024	Byproduct of the disinfection process	n/a	0
Chloride (ppm)	250 <sup>4,6</sup>	n/a	69.0	37.0 – 69.0	2024	Naturally occurring	n/a	0
Chromium, hexavalent (ppb)	13 <sup>6</sup>	n/a	1.30	1.1 – 1.3	2023 <sup>2</sup>	Naturally occurring	n/a	0
Dieldrin (ppb)	0.2	n/a	0.008	ND – 0.014	2024	Residue of banned pesticide	n/a	0
Sodium (ppm)	60 <sup>4</sup>	n/a	37.0	29.0 – 37.0	2023 <sup>2</sup>	Naturally occurring	n/a	0
Strontium (ppb)	4000 <sup>6</sup>	n/a	81.0	62.0 – 81.0	2022 <sup>2</sup>	Naturally occurring	n/a	0
Sulfate (ppm)	250 <sup>4</sup>	n/a	13.0	9.2 – 13.0	2024	Naturally occurring	n/a	0
Vanadium (ppb)	21 <sup>6</sup>	n/a	10.0	9.3 – 10.0	2022 <sup>2</sup>	Naturally occurring	n/a	0

**Disinfection Byproducts**

**Table 1-5**

Contaminants (units)	MCL (Allowed)	MCLG (Goal) <sup>2</sup>	Highest Level Detected	Range of Detection	Year of Sample	Typical Sources of Contaminants	Violation	# of Sites Exceeding the Action Level
Total Trihalomethanes (TTHM) (ppb)	80	n/a	ND	ND <sup>1</sup>	2024	Byproduct of drinking water disinfection	No	0

**Navy – Internal Monitoring of DCP at Waiawa**

**Table 1-6**

Contaminants (units)	MCL (Allowed)	MCLG (Goal) <sup>2</sup>	Highest Level Detected	Range of Detection	Year of Sample	Typical Sources of Contaminants	Violation	# of Sites Exceeding the Action Level
1,2-Dichloropropane (DCP)	5	0	ND	ND <sup>1</sup>	2024	Discharge from industrial chemical factories	No	0

After the November 20, 2021, fuel release and issuance of the DOH Health Advisory, extensive testing was conducted to initially determine the level of contamination present, and later to confirm that system flushing was effective. The extensive testing ended in March 2025. In March 2026, after reviewing the laboratory data from both the LTM and EDWM, EPA endorsed the closure of both sampling programs and confirmed that JP-5 is no longer present in the JBPHH drinking water system.

Table 1-7 lists contaminants detected by the Long-Term Monitoring Plan and the Extended Drinking Water Monitoring Plan, levels detected, as well as corrective actions taken.

2025 Contaminant Detections in Distribution System/Residences

Table 1-7

Monitoring Program Name (Duration)	Contaminants (units)	MCL (Allowed)	Highest Level Detected	# of Sites Exceeding the Action Level	Corrective Actions
Extended Drinking Water Monitoring Plan (MAR 2024 – MAR 2025)	Copper (ppm)	AL = 1.3	0.33	0	n/a
	Lead (ppb)	AL = 10	9	0	n/a
	Total Trihalomethanes (ppb)	80	45.4	0	n/a
	Total Petroleum Hydrocarbons (diesel) (ppb)	Corrective action is required at any detection.	0	0	n/a
	Total Petroleum Hydrocarbons (gasoline) (ppb)	Corrective action is required at any detection.	0	0	n/a
	Total Petroleum Hydrocarbons (oil) (ppb)	Corrective action is required at any detection.	0	0	n/a

**Table Definitions:**

- AL Action Level.** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- EAL Environmental Action Level.** Environmental Action Levels are concentrations of contaminants in drinking water and other media (e.g., soil, soil gas, and groundwater) below which the contaminants are assumed to not pose a significant threat to human health or the environment. Exceeding the EAL does not necessarily indicate that contamination at the site poses environmental hazards but generally warrants additional investigation.
- ISP Incident Specific Parameter.** The Hawaii DOH uses multiple criteria to assess the safety of the drinking water including maximum contaminant levels (MCLs), previously established action levels (ALs), health advisory levels (HALs), and incident specific parameters (ISPs).
- J** Estimated Value

- MCL Maximum Contaminant Level.** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.
- MCLG Maximum Contaminant Level Goal.** The level of contamination in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MRDL Maximum Residual Disinfectant Level.** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- MRDLG Maximum Residual Disinfectant Level Goal.** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Table Abbreviations:**

- n/a** not applicable.
- ppb** parts per billion or micrograms per liter.
- ppt** parts per trillion or nanograms per liter.
- ND** not detectable at testing limits.
- ppm** parts per million or milligrams per liter.

**Table Notes:**

1. Only one sample was collected.
2. The State and EPA require us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. The date of the last sample collected is as indicated.
3. These results are for informational purposes. There are no set standards. EPA will use this data to help determine where certain contaminants occur and whether it needs to regulate these contaminants. At this time, these contaminants do not have MCLs or MCLGs.
4. These are Secondary Maximum Contaminant Levels not enforced by EPA.
5. After each quarter, a running average is calculated using the preceding 12 months of data. This value is the highest running average for the year.
6. National Secondary Drinking Water Regulations (NSDWRs), or secondary standards, are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects in drinking water. EPA recommends secondary standards to water systems but does not require systems to comply with the standard.
7. These lead and copper results were collected under the LTM and EDWM programs which differ from the sampling done under the LCR.

**Note:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline 1-800-426-4791.