
# TUA Decision Process

Navy/DLA will propose the best available practicable technology for a Tank Upgrade Alternative (TUA) EPA/DOH will then evaluate and make a determination



14 March 2018

# TANK UPGRADE ALTERNATIVE (TUA) AND ALTERNATIVE LOCATION STUDY SUMMARY

The TUA Report evaluated six alternatives (three single wall/three double wall) and the preliminary alternative location study identified a suitable site on Oahu

TUA	Description	ROM Cost Per Tank (\$M)	Number of Tanks (% capacity)	Project End Date
<b>1A</b>	Restoration of Existing Tank	\$10-25	18 (100%)	2031
<b>1B</b>	Restoration of Existing Tank plus Interior Coating	\$25-100	18 (100%)	2037
1D	Remove existing Liner, Install New Steel Liner with Interior Coating	\$100-250	18 (100%)	2038
<b>2A</b>	Composite Tank (Double Wall) Carbon Steel, with Interior Coating	\$25-100	20 (88%)	2040
<b>2B</b>	Composite Tank (Double Wall) Stainless Steel	\$100-250	20 (88%)	2037
<b>3A</b>	Tank within a Tank (Carbon Steel), full Interior and Exterior Coating	\$100-250	20 (80%)	2038
Alt	New Tanks (Cut and Cover)	\$100-250	40 (100%)	<u>2051</u>

# TUA Report

## Rated 18 attributes:

- Constructible
- Testable
- Inspectable
- Repairable
- Practicable
- Corrosion damage mechanism
- Successful implementation elsewhere
- Reliability
- Impact on storage volume
- Secondary containment

- Dependency on existing liner
- Release detection integral to construction
- Testing & Commissioning
   Procedures
- Pre-TIRM requirements
- Post-TIRM requirements
- Impact on Operations/
   Maintenance
- Cost
- Duration

# Alternative Location Study

Screened 12 sites that could meet the following requirements:

- Support JBPHH (Oahu)
- Energy Independent
- Secure (Cyber, Missile)
- Capacity
- EV Regulations

Preliminary Results: Kapūkaki


Many factors have to be considered and weighted objectively when deciding on the best available practicable technology

# Alternatives Construction Summary


The TUA Report rated attributes for three single wall tank and three double wall tank upgrade variations.

An Alternative Location Study is now complete for a double wall tank variant.


1A – New TIRM



# 1B – 1A + Coating



1D – New Liner



# Pros:

- Readily Inspectable
- Lowest Project Risk

# Cons:

No secondaryContainment

### Pros:

- Readily Inspectable
- Low Project Risk
- Additional barrier

### Cons:

No secondaryContainment


# Pros:

- Readily Inspectable
- Complete new liner


# Cons:

- No secondaryContainment
- High Project Risk


2A – Composite
Carbon Steel



2B – Composite
Stainless Steel



Alt – Cut and Cover



#### Pros:

- Complete new inner liner
- Secondary Containment

#### Cons:

- High Project Risk
- Not tried on this scale

Pros:

- Complete new SS inner liner
- Secondary Containment

#### Cons:

- High Project Risk
- Not tried on this scale

### Pros:

- Complete new inner liner

3A – Tank in a

Tank

- Secondary Containment

#### Cons:

- High Project Risk
- Not tried on this scale
- Seismic concerns

#### Pros:

- Readily Inspectable
- Complete new Tank
- Proven Design

#### Cons:

- Longest time to construct
- Most Costly

# Alternative Site Study

PURPOSE: To determine to see what, if any, location is feasible to meet the constraints and requirements.

# IDENTIFICATION AND SELECTION OF SITES



#### CONSTRAINTS

- Located on Oahu to Support JBPHH
- Meet all Environmental Regulations & Laws
- Equivalent Capability to Red Hill

#### TWELVE SITES EVALUATED

- Two eastern Sites
- Six Lower Elevation Sites near JBPHH
- Four Upper Elevation Sites

#### TANK REQUIREMENTS

- Field Constructed, Underground Storage Tank (Cut-and-Cover)
- Double-Wall with Continuous Interstitial Monitoring
- Quantity & Size: 40 Tanks, 150,000 bbl each, 150' wide X 52' tall


Preliminary Alternate Candidate Site: KAPŪKAKI

# Alternative Site Study

# KAPŪKAKI

# ARTIST RENDERING OF CONCEPT





### TANK DESIGN/CONSTRUCTION REQUIREMENTS

- Complies With All Current Regulations:
  - UFC 3-460-01 Design: Petroleum Fuel Facilities
  - DoD Standard Design AW 78-24-33 Cut-and-Cover Tank
- Tank Type:
  - Field Constructed
  - Double-Wall with Continuous Interstitial Monitoring
  - Quantity & Size: 40 Tanks, 150,000 bbl each, 150' wide X 52' tall
- Estimated Completion Date 2051


### CONCEPT ONLY

# RELEASE DETECTION

The Navy is committed to installing the best release detection system available.

# Custom Release Detection Systems


- \*Improves upon existing capability
- \*No off-the-shelf systems
- \*Three vendors have developed Red Hill specific systems
- \*All tanks that are in service have received a passing result since 2015



# On-site testing is in progress







Expectations

 Provides more continuous and precise monitoring Systems that meet or exceed regulatory requirements

The combination of enhanced, permanent release detection along with other upgrades greatly reduces the risk for single walled tanks.